

**Will County Health Department  
Environmental Laboratory Test Results**

Report Date: 7/3/2023

501 Ella Avenue  
Joliet, IL 60433  
(815) 727-8517


I.D.P.H. Certificate #17524

<b>Sample ID:</b> 2306301424	<b>Type:</b> Potable	<b>Sample</b>	
<b>Cust. Sample:</b> 4175861	<b>Project:</b> Routine Bacterial Screen - Count	<b>Address:</b>	<b>NEW LENOX AND COOPER RD</b>
	<b>Source:</b> NCPWS	<b>Sampler:</b>	<b>NEW LENOX IL 60451</b>
	<b>Chlorination:</b> UV light	<b>Location:</b>	Brozman, Matthew
		<b>Purpose:</b>	sample tap
<b>LENOX PARK DIST WALKER PARK WA552</b>		<b>Collected:</b>	Clearance #1
<b>701 W HAVEN AVE STE A</b>		<b>Received:</b>	6/30/2023 11:25
<b>NEW LENOX, IL 60451</b>		<b>Completed:</b>	6/30/2023 11:50
			7/1/2023

Analysis	Date Time	Result Units	Results Indicate
Routine Bacterial Screen - Count			
Coliform/ Total -Quantitative	6/30/2023 15:36	0 MPN	This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.
Escherichia coli - Quantitative	6/30/2023 15:36	0 MPN	This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.

**Conclusions:**

**Notes:** IL3159246

  
Trisha Kautz  
Laboratory Coordinator

\_\_\_\_\_  
Chemistry Analyst

  
\_\_\_\_\_  
Microbiology Analyst

*The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.*

**Will County Health Department  
Environmental Laboratory Test Results**

Report Date: 7/5/2023

501 Ella Avenue  
Joliet, IL 60433  
(815) 727-8517

I.D.P.H. Certificate #17524

<b>Sample ID:</b> 2307031200	<b>Type:</b> Potable	<b>Sample</b>	<b>NEW LENOX AND COOPER RD</b>
<b>Cust. Sample:</b> 4175698	<b>Project:</b> Routine Bacterial Screen - Count	<b>Address:</b>	<b>NEW LENOX IL 60451</b>
	<b>Source:</b> NCPWS	<b>Sampler:</b>	Brozman, Matthew
	<b>Chlorination:</b> UV light	<b>Location:</b>	sample tap
<b>LENOX PARK DIST WALKER PARK WA552</b>		<b>Purpose:</b>	Clearance #2
<b>701 W HAVEN AVE STE A</b>		<b>Collected:</b>	7/3/2023 10:50
<b>NEW LENOX, IL 60451</b>		<b>Received:</b>	7/3/2023 11:48
		<b>Completed:</b>	7/5/2023


Analysis	Date Time	Result Units	Results Indicate
Routine Bacterial Screen - Count			
Coliform/ Total -Quantitative	7/3/2023 15:25	0 MPN	This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.
Escherichia coli - Quantitative	7/3/2023 15:25	0 MPN	This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.

**Conclusions:**

**Notes:** WA552 IL3158246

  
Trisha Kautz  
Laboratory Coordinator

\_\_\_\_\_  
Chemistry Analyst

  
\_\_\_\_\_  
Microbiology Analyst

*The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.*