

**Will County Health Department  
Environmental Laboratory Test Results**

Report Date: 7/26/2023

501 Ella Avenue  
Joliet, IL 60433  
(815) 727-8517

I.D.P.H. Certificate #17524

<b>Sample ID:</b> 2307251515	<b>Type:</b> Potable	<b>Sample</b>	<b>NEW LENOX AND COOPER RD</b>
<b>Cust. Sample:</b> 4176017	<b>Project:</b> Routine Bacterial Screen	<b>Address:</b>	<b>NEW LENOX IL 60451</b>
	<b>Source:</b> NCPWS	<b>Sampler:</b>	Shultz, Lauren
	<b>Chlorination:</b> UV light	<b>Location:</b>	sample tap
<b>LENOX PARK DIST WALKER PARK WA552</b>		<b>Purpose:</b>	Routine
<b>701 W HAVEN AVE STE A</b>		<b>Collected:</b>	7/25/2023 12:16
<b>NEW LENOX, IL 60451</b>		<b>Received:</b>	7/25/2023 14:45
		<b>Completed:</b>	7/26/2023

Analysis	Date Time	Result Units	Results Indicate
Routine Bacterial Screen			
Coliform/ Total -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.
Escherichia coli -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.


**Conclusions:**

**Notes:** IL3158246. 1 OF 3.



Trisha Kautz  
Laboratory Coordinator

Chemistry Analyst

  
Microbiology Analyst

*The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.*

**Will County Health Department  
Environmental Laboratory Test Results**

Report Date: 7/26/2023

501 Ella Avenue  
Joliet, IL 60433  
(815) 727-8517


I.D.P.H. Certificate #17524

<b>Sample ID:</b> 2307251516	<b>Type:</b> Potable	<b>Sample</b>	<b>NEW LENOX AND COOPER RD</b>
<b>Cust. Sample:</b> 4176018	<b>Project:</b> Routine Bacterial Screen	<b>Address:</b>	<b>NEW LENOX IL 60451</b>
	<b>Source:</b> NCPWS	<b>Sampler:</b>	Shultz, Lauren
	<b>Chlorination:</b> UV light	<b>Location:</b>	sample tap
<b>LENOX PARK DIST WALKER PARK WA552</b>		<b>Purpose:</b>	Routine
<b>701 W HAVEN AVE STE A</b>		<b>Collected:</b>	7/25/2023 12:17
<b>NEW LENOX, IL 60451</b>		<b>Received:</b>	7/25/2023 14:45
		<b>Completed:</b>	7/26/2023


<b>Analysis</b>	<b>Date Time</b>	<b>Result Units</b>	<b>Results Indicate</b>
Routine Bacterial Screen			
Coliform/ Total -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.
Escherichia coli -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.

**Conclusions:**

**Notes:** IL3158246. 2 OF 3.

  
Trisha Kautz  
Laboratory Coordinator

\_\_\_\_\_  
Chemistry Analyst

  
\_\_\_\_\_  
Microbiology Analyst

*The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.*

**Will County Health Department  
Environmental Laboratory Test Results**

Report Date: 7/26/2023

501 Ella Avenue  
Joliet, IL 60433  
(815) 727-8517

I.D.P.H. Certificate #17524

<b>Sample ID:</b> 2307251517	<b>Type:</b> Potable	<b>Sample</b>	<b>NEW LENOX AND COOPER RD</b>
<b>Cust. Sample:</b> 4176019	<b>Project:</b> Routine Bacterial Screen	<b>Address:</b>	<b>NEW LENOX IL 60451</b>
	<b>Source:</b> NCPWS	<b>Sampler:</b>	Shultz, Lauren
	<b>Chlorination:</b> UV light	<b>Location:</b>	sample tap
<b>LENOX PARK DIST WALKER PARK WA552</b>		<b>Purpose:</b>	Routine
<b>701 W HAVEN AVE STE A</b>		<b>Collected:</b>	7/25/2023 12:18
<b>NEW LENOX, IL 60451</b>		<b>Received:</b>	7/25/2023 14:45
		<b>Completed:</b>	7/26/2023

<b>Analysis</b>	<b>Date Time</b>	<b>Result Units</b>	<b>Results Indicate</b>
Routine Bacterial Screen			
Coliform/ Total -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.
Escherichia coli -Qualitative	7/25/2023 14:57	Absent /100mL	This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample.

**Conclusions:**

**Notes:** IL3158246. 3 OF 3.



Trisha Kautz  
Laboratory Coordinator

Chemistry Analyst

Microbiology Analyst

*The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. This report shall not be reproduced, except in full, without the written approval of the laboratory.*