

**Will County Health Department
Environmental Laboratory Test Results**

Report Date: 5/1/2024

501 Ella Avenue
Joliet, IL 60433
(815) 727-8517

I.D.P.H. Certificate #17524
NELAP Accreditation #100322

Sample ID: 2404301114
Cust. Sample: 417131

Type: Potable
Project: Routine Bacterial Screen
Source: NCPWS
Chlorination: UV light


Sample Address: NEW LENOX AND COOPER RD
NEW LENOX IL 60451
Sampler: Schultz, Lauren
Location: sample tap
Purpose: Routine
Collected: 4/29/2024 10:02
Received: 4/30/2024 8:23
Completed: 5/1/2024

**LENOX PARK DIST WALKER PARK WA552
701 W HAVEN AVE STE A
NEW LENOX, IL 60451**

| Analysis | Date Time | Result Units | Results Indicate |
|-------------------------------|-----------------|---------------|---|
| Well screening | | | |
| Coliform/ Total -Qualitative | 4/30/2024 15:40 | Absent /100mL | This test shows no evidence of bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample. |
| Escherichia coli -Qualitative | 4/30/2024 15:40 | Absent /100mL | This test shows no evidence of Escherichia coli bacterial pollution occurring at this time. We recommend re-sampling every 6 to 12 months. SM 21st ed. 9223B was used to analyze 100mL of the sample. |


Conclusions:

Notes: IL3158246



Trisha Kautz
Laboratory Operations Director

Chemistry Analyst



Microbiology Analyst

The Laboratory claims responsibility for analysis only. No responsibility is assumed for specimen collection, preservation, storage, and transport. Sample results relate only to the analytes of interest tested. The laboratory is not NELAP accredited for non-potable chemistry analyses. This report shall not be reproduced, except in full, without the written approval of the laboratory.